



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated

23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00125NML13985

Issued Date : 05-11-2025

Organization Type : Educational Institutions

Expiry Date : 04-11-2026

Name of the Organization : SRI VANI INTERNATIONAL SCHOOL

Address : SANKARI MAIN ROAD, UPPUPALAYAM,

KUMARAPALAYAM TK, NAMAKKAL DT

I, **PRAKASH N** owner/manager of the **SRI VANI INTERNATIONAL SCHOOL** functioning as **Educational Institutions** located at **Padaveedu** in **Namakkal** district hereby declare that

- This Self-Declared Sanitation certificate is valid from **05-11-2025** to **04-11-2026** and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate **1500** people/pupils and has **54** urinals and **43** toilets which is proportionate to the number of users as per government norms.
- **12** Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

Signature of the Owner/Manager



(அ) TN00125NML13985 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளிடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பாரகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a) Keying in the unique certificate number TN00125NML13985 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.



TAMIL NADU WATER SUPPLY & DRAINAGE BOARD
DISTRICT LEVEL WATER TESTING LABORATORY

Room No 304, Collector office Annexure building, Namakkal.

Ph: 04286-294620

TEST REPORT

From
S.C.Prakasham,B.Sc.,
Junior Water Analyst,
TWAD Board, DWT Lab,
Namakkal.

To
The Principal,
Sri Vani International School,
Sankari Main road,Uppupalayam,
Komarapalayam Taluk,
Namakkal.

Lr.No: 3859/JWA/TWAD Lab/ NKL /2023/Dated: 08.01.2024

Sir,

Sub: Examination of water sample - Report furnished - Reg.

Ref : 1) Your Lr.No Nil/dt - 06.01.2024

2) T.O Invoice No.5706/dt - 06.01.2024 for Rs1652/-

The results of analysis for the given water sample sent under reference is furnished below.

Sample No	3859		
Date of Collection	06.01.2024		
Date of Receipt	06.01.2024		
Sampling Location	RO - Outlet Water		
Location	Sri Vani International school		
Habitation	Komarapalayam		
District	Namakkal		
Collected by	Principal		
BIS 10500 : 2012	Acceptable limit	Permissible limit in the absence of alternate source	Result for Water sample No:
I PHYSICAL EXAMINATION			3859
1 Appearance	--	--	Clear
2 Colour (Pt.Co - scale)	5	15	Colour less
3 Odour	Agreeable	0	None
4 Turbidity NT units	1	5	0
5 Total dissolved solids, mg/L	500	2000	78
6 Electrical conductivity micro mho/cm	--	--	112
II CHEMICAL EXAMINATION			
7 pH	6.5 to 8.5	6.5 to 8.5	7.02
8 Ph-Alkalinity as CaCO ₃ mg/L			0
9 Total Alkalinity CaCO ₃ mg/L	200	600	24
10 Total Hardness as CaCO ₃ mg/L	200	600	20
11 Calcium as Ca mg/L	75	200	5
12 Magnesium as Mg mg/L	30	100	2
13 Sodium as Na mg/L	--	--	0
14 Potassium as K mg/L	--	--	0
15 Iron as Fe mg/L	0.3	1.0	0
16 Manganese as Mn mg/L	0.1	0.3	0
17 Free Ammonia as NH ₃ mg/L	0.5	0.5	0
18 Nitrite as NO ₂ mg/L	--	--	0
19 Nitrate as NO ₃ mg/L	45	45	2
20 Chloride as Cl mg/L	250	1000	16
21 Fluoride as F mg/L	1	1.5	0
22 Sulphate as SO ₄ mg/L	200	400	4
23 Phosphate as PO ₄ mg/L	--	--	0
24 Tidy's Test 4hrs as O ₂ mg/L	--	--	-
25 Free residual chlorine mg/L	0.2	1.0	0
III BACTERIOLOGICAL EXAMINATION			
26 Fecal Coliform on /100ml	0	0	0/100ml

REPORT: The given water sample is Physically and chemically potable and bacteriologically not contaminated.

Junior Water Analyst,
TWAD Board, DWT Lab,
Namakkal.